



DELLAVALLE®
Laboratory, Inc.
Chemists and Consultants

Bacteriological Water Analysis

1910 W. McKinley, Suite 110, Fresno, CA 93728
FAX (559) 268-8174 - (800) 228-9896 - (559) 233-6129

Sedona Geologic
2904 N Thorne Avenue
Fresno CA 93704
17345
50

Material Submitted: Water

Lab No. 180896
Sampler Client
Submitted Date 11/6/2012
Submitted by
Reported Date 11/7/2012
Location/Project
Copy To
Fax
e-mail cskelton@sedonageologic.com

	Date Sampled	Time Sampled	Date Started	Time Started	Rec'd Temp °C	Total MPN Coliform per 100 ml	MPN E-Coli per 100 ml	Residual Chlorine mg/L
RL--->						< 1	< 1	
SM--->						9223	9223	Field test
Analysis Date:			11/7/2012	11/7/2012	11/7/2012	11/7/2012	11/7/2012	

001	GW - B - 3	11/6/2012	12:30	11/6/2012	16:05	19.3	>2419.6	135.4
002	GW - B - 2	11/6/2012	12:50	11/6/2012	16:05	19.3	>2419.6	1.0

< 1 = Absent

ND = None Detected

SM = Standard Methods for the Examination of Water and Wastewater, 19th ed., 1995

Records retained for 5 yrs.

Approved By: _____
ELAP Certification #1595